




Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



EC TYPE EXAMINATION		Certificate N°
In accordance with module B of the Marine Directive 2014/90/EU on Equipment Directive		13/SP/2992-1-REV 0
Manufacturer	Name	Industrias AUCA S.L.
	Address	Pol. Ind. Alqueria de Mina Calle Tappissers, 3 SP - 46200 Paiporta (Valencia) SPAIN
<p>Concerned Equipment: Item n° A.1/3.2 : Portable Stored Pressure Fire Extinguisher</p> <p>Type: PP 2 P</p> <p>Nominal charge: 2 kg. Powder</p> <p>Fire ratings: 13A – 89B - C</p> <p>Temperature range: min.-30°C / max. +60°C</p> <p>EN3-7 Test report : APRAGAZ n° EN 10443</p>		
<p>The manufacturer is allowed to affix the marine CE mark  (followed by the NOBO n° and the year of manufacturing) to the approved equipment in the conditions described in article 10 of the Directive, only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 01/02/2023</p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/90/EU, certifies that the types of these extinguishing systems conforms to the relevant requirements of the pertinent EN3 standards and the Marine Equipment Directive 2014/90/EU as amended on basis of the documentation and samples supplied for review and approval.</p>		
Date : 05/02/2018	Name : Ch. Leplat	Positior General Manager
Notified body identification number :	0029	Signature
Notified body stamp :	APRAGAZ Belgium Inspecting Authority	
Notified body reference :	P4575/015	