





Chaussée de Vilvorde, 156 Vilvoordsesteenweg 156 B-1120 Bruxelles/Brussel Tel.: 32 (0)2 264 03 60 Fax: 32 (0)2 268 89 58 http://www.apragaz.com info@apragaz.com

Cert Nº 084-PROD

NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 96/98/EC as amended

Certificate N° 15/SP/3574-0-REV 0

Manufacturer	Name	Industrias AUCA S.L.
	Address	Pol. Ind. Alqueria de Mina Calle Tappissers, 3 SP - 46200 Paiporta (Valencia) SPAIN

Concerned Equipment: Item n° A.1/3.2 : Portable Stored Pressure Fire Extinguisher

Type: PP 9 P / PP 9 HDI

Nominal charge: 9 kg. Powder, PP9P: ABC 30 (Effective 30) / PP9PHDI: ABC 40 (Radikal 40)

Fire ratings: PP9P: 43A - 233B - C / PP9PHDI: 55A - 233B - C

Temperature range: min.-20°C / max. +60°C

EN3-7 Test certificate: AFNOR: PP9P: EP9 153 531 A0 / AFNOR PP9HDI: EP9 153 532 A0

The manufacturer is allowed to affix the marine CE mark followed with our notified body identification n° 0029 to the approved equipment in the conditions described in article 11 of the Directive, only if the requirements stated in Module D are fully complied with.

The approval is valid until 01/03/2020

APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 96/98/EC, certifies that the types of these extinguishing systems conforms to the relevant requirements of the pertinent EN3 standards and the Marine Equipment Directive 96/98/EC as amended on basis of the documentation and samples supplied for review and approval.

Signature

Date: 02/03/2015 Name: Ch. Leplat Position General Manager

Notified body identification **0029**

number:

APRAGAZ

Notified body stamp : Belgium Inspecting

Authority

Notified body reference : P4575/023

RP181 rev 0